

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 296Dated: 15/04/24

It is certified that an inspection team headed by Anjali Jain
(Name of Officers with designation) from Chemist

PHED inspected the **BELLWETHER INTERNATIONAL SCHOOL, KATNI, DIST KATNI, MP** on 08/04/24
and on the basis of Water Test Report (Attached) bearing no. P.N.A./296 dated 15/04/24 of
District Laboratory P. H. E. Dept., Katni (PHED Lab)

certified that the **BELLWETHER INTERNATIONAL SCHOOL, KATNI, DIST KATNI, MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with seal

:-

Name

:- ANSHUL BAI PAI

Designation

:- Public Health Engg.
Sub.Division-KATNI (M.P.)

Name & address of the office/Department: - _____


To,
**BELLWETHER INTERNATIONAL SCHOOL,
KATNI, DIST KATNI, MP**

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies



Principal
Bellwether International School
KATNI (M.P.)



लाला यथुरा दास शिक्षा समिति
कटनी (म.प्र.)

P.N.A./296

DISTRICT LABORATORY
P.H. E. DEPARTMENT KATNI (M.P.) 483501
ANALYSIS - REPORT

Source of Sample	tubewell				
1. PARTICULAR OF SENDER -					
A. Sample collected from	Bellwather international school , Katni (MP)				
B. Sample Submitted By	Bellwather international school , Katni (MP)				
2. PARTICULAR OF SAMPLE					
A. Date of submitted in Lab	08.04.2024 at 1.25 pm				
3. PARTICULARS TO BE FILLED IN LABORATORY					
A. Date of Receipt	08.04.2024				
B. Sample Analysed on Date	12.04.2024				
4. DETAILS OF SAMPLE					
1 Bellwather international school , Katni (MP)					
S.No.	Characteristics	Units	BIS Standard:IS:10500:2012 (Rev.2)		Results
			Desirable limits	Permissible limits in the absence of alternative source	
1	Apperance		Crystal Clear	-	Clear
2	Temperature	0c		-	28
3	Colour	hazen	5	15	1
4	Odour		Unobjectionable	-	unobjectionable
5	Turbidity	NTU	1	5	0.2
6	TDS	Mg/l	500	2000	233.6
7	pH Value		6.5 to 8.5	No relaxation	6.65
8	Total Hardness (as CaCO3)	Mg/l	200	600	180
9	Alkalinity	Mg/l	200	600	50
10	Chloride(asCl)	Mg/l	250	1000	70
11	Iron(asFe)	Mg/l	1	No relaxation	0.20
13	Manganese (as Mn)	Mg/l	0.1	0.3	Nil
14	Fluoride(asF)	Mg/l	1.0	1.5	0.18
15	Bactrological Test	per 100 ml	Should Be Zero		Nil

Note :-

- 1 The figures indicated under the column "Desirable" bare the limits upto which water is generally acceptable to the consumers.
Figures in excess of those mentioned under " Permissible limits" render the water not acceptable but still may be tolerated in the absence of an alternative and better source but upto the limits indicated under colum "Cause for Rejection" above which the source will have to be rejected.
- 2
- 3 This test report is not liable for any binding to the court of the law else where.
- 4 This test report is as per the sample submitted by the party for testing.
- 5 Please take necessary action as per required of BIS Standard limits.
- 6 Always send water samples in sterilized bottle for BACTERIOLOGICAL (COLIFORM) TEST.

Anup Singh
Chemist 15/4/24

District Laboratory
P.H.E.D. Katni, MP
District Laboratory
P.H.E.D. Katni

[Signature]
Principal
Bellwether International School
KATNI (M.P.)

[Signature]
सचिव
लाला मथुरा दास शिक्षा समिति
कटनी (म.प्र.)